



## AENOR Product Certificate



B18/000009

AENOR certifies that the organization

### FUCOLI-SOMEPAL FUNDIÇÃO DE FERRO, S.A.

registered office CL ESTRADA DE COSELHAS 3001-906 COIMBRA (Portugal)

supplies **Isolating valves for water supply**

in compliance with UNE-EN 1074-1:2001 (EN 1074-1:2000)  
UNE-EN 1074-1:2001 ERRATUM:2008  
UNE-EN 1074-2/A1:2004 (EN 1074-2:2000/A1:2004)  
UNE-EN 1074-2:2001 (EN 1074-2:2000)

References Specified in Annex to the Certificate

Production site RUA DE AVEIRO, 50 3050-903 PAMPILHOSA (Portugal)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP B18.01.

This certificate supersedes B18/000009, dated 2023-09-21

First issued on 2018-09-21  
Modified on 2024-04-11  
Validity 2028-09-21

Rafael GARCÍA MEIRO  
CEO

# AENOR



## AENOR Product Certificate

B18/000009

### Annex to Certificate

Trade Mark	Type of valve	Type of flow	Type of seal
FUCOLI-SOMEPAL	GATE	COMPLETE	ELASTIC

Model	Type of ends	PN	Service temperatures	DN
NEXUS BLOCKPLUS	PVC SOCKET CONNECTION AUTOBLOCK	16	0 / 70 °C	50, 65, 80, 100, 125, 150, 200
NEXUS	FLANGE	16	0 / 70 °C	40, 50, 65, 80, 100, 125, 150, 200, 250, 300
NEXUS	PVC SOCKET CONNECTION	16	0 / 70 °C	50, 65, 80, 100, 125, 150, 200, 250
NEXUS	FLANGE/PE SPIGOT END	16	0 / 40 °C	50, 65, 80, 100, 125, 150, 200

First issued on 2018-09-21  
Modified on 2024-04-11  
Validity 2028-09-21



**AENOR CONFÍA S.A.U.**  
Génova, 6. 28004 Madrid. España  
Tel. 91 432 60 00.- [www.aenor.com](http://www.aenor.com)